

First buried muon counter prototype for the Auger Observatory

I. P. Sidelnik¹, B. Wundheiler¹, E. Colombo¹, A. Etchegoyen¹, A. Ferrero¹, M. Platino¹, O. Wainberg¹

¹ *Centro Atómico Constituyentes (Comisión Nacional de Energía Atómica/CONICET/UTN-FRBA)*

Abstract. AMIGA (Auger Muons and Infill for the Ground Array) constitutes an enhancement for the Pierre Auger Observatory. It consists of a denser array of surface detectors and muon counters whose objective is both to extend the detection range down to 10^{17} eV and to help towards mass composition determination. The latter is to be achieved with muon counters since the shower muon content is one of the best parameter for particle type identification. In this work, we present the study of a muon counter prototype. The prototype was buried 3 m deep in an effort to avoid signal contamination from the shower electromagnetic component. We study the performance of the detector before and after burying it with its associated electronic components. The detector validation is performed from signal analysis of charged particles traversing the counter.

1. Introduction

The cosmic ray energy spectrum presents four main features (Nagano & Watson, 2000) which give rise to abrupt spectral index changes: the knee, the second knee, the ankle and the GZK cutoff. The knee is at $\sim 4 \times 10^{15}$ eV, the second knee at $\sim 4 \times 10^{17}$ eV, the ankle at $\sim 3 \times 10^{18}$, and finally the GZK cutoff, i.e. the suppression of the cosmic ray flux at energies above $\sim 4 \times 10^{19}$ eV. The Auger collaboration has recently shown experimental evidence of the ankle (Tokonatsu, 2007), the GZK-cutoff (Abraham et al., 2008a), and of the anisotropy in the arrival direction of the cosmic rays with energies above $\sim 6 \times 10^{19}$ eV (Abraham et al., 2008a) which is a further confirmation of the flux cutoff.

The ankle region may actually be considered as a dip raging from the second knee up to $\sim 10^{19}$ eV and in an attempt to fully study these two spectrum traits Auger is building two detector enhancements: AMIGA (Etchegoyen, 2007) and HEAT (High Elevation Auger Telescopes) (Klages, 2007). The physical interpretations of the second knee and ankle are not yet clear but still they are closely linked. They are assumed to be related to the transition from galactic to extra-galactic cosmic ray sources and from dominant heavy to dominant light primary compositions (Allard et al., 2005, Berezhinsky et al., 2004, Wibig and Wofendale, 2005).

The Pierre Auger Observatory (Abraham et al., 2004) is built to detect cosmic rays of the highest energy with two distinct design features, a large size and a hybrid detection system in an effort to detect a large number of events per year with reduced systematic uncertainties. It will have a southern and a northern

component. The former is located in the west of Argentina, in the Province of Mendoza where it spans an area of 3000 km^2 covered with a surface detector (SD) system of 1600 water Cherenkov detectors (Allekote et al., 2008) deployed on a 1500 m triangular grid plus four buildings on the array periphery lodging six fluorescence detector (FD) telescopes each one with a $30^\circ \times 30^\circ$ elevation and azimuth field of view. As above mentioned it now encompasses two enhancements and in this work we are going to concentrate on the AMIGA muon counters.

2. AMIGA muon counters

The Observatory was original designed to be fully efficient at $\sim 3 \times 10^{18} \text{ eV}$ for the surface array and at $\sim 10^{18} \text{ eV}$ for the hybrid mode. The enhancements (see Fig. 1) will extend these efficiencies down to 10^{17} eV and $\sim 2 \times 10^{17} \text{ eV}$, respectively. Decreasing energies imply both a flux increment and a smaller shower lateral distribution spread and therefore AMIGA will encompass a smaller area with a denser array (Etchegoyen, 2007).




Figure 1. Auger enhancements layout. Light and dark lines limit the $0^\circ - 30^\circ \times 0^\circ - 30^\circ$ and $30^\circ - 60^\circ \times 0^\circ - 30^\circ$ elevation and azimuth field of view for the original 6 fluorescence telescopes and the HEAT 3 telescopes on Cerro Coihueco, respectively. The two hexagons limit the AMIGA areas of 5.9 and 23.5 km^2 with 433 and 750 m triangular grid detector spacings, respectively. Each dot within these hexagons represents a pair of a water Cherenkov tank and a muon counter. The center dot is the Constanza pair placed $\sim 6.0 \text{ km}$ away from Cerro Coihueco.

The muon number and X_{max} (the position where the airshower attains its maximum development) are the best two indicators of the chemical composition of cosmic rays. Auger measures X_{max} using its fluorescence telescopes and it will measure the shower muon content (Supanitsky et al., 2008) with plastic scintillators. To achieve this objective, along with each SD of the graded denser array, a 30 m^2 area muon counter will be buried in order to avoid electromagnetic contamination.. A first 5 m^2 module will be buried $2.25 \pm 0.05 \text{ m}$ underground by the end of 2009. The scintillator modules are not supposed to reconstruct the




Figure 2. Muon counter main features and schematics of the experimental setup. *lhs*: Detail of the electronic underground enclosure. *rhs*: Coincidence box used as an external trigger, dash line points to experimental setup inside the box (not in scale).

shower parameters (which will be performed by the FD and SD systems) but just to count muons.

The scintillator strips were developed following the MINOS design (MINOS, 1998) at the “Scintillator Fabrication Facility” at the Fermi National Accelerator Laboratory (FNAL). Seven counters will be buried by the beginning of 2011 and each of these counters will have four modules with 4.1 cm wide $\times$ 1.0 cm high strips, two of them 400 cm long and the other two 200 cm long, in order to check pileup close to the shower core. They are made of extruded polystyrene doped with fluors and co-extruded with a TiO_2 reflecting coating with a groove in where a wave length shifter (WLS) fiber is glued and covered with a reflective foil (Etchegoyen, 2007). Each module will consist of 64 strips with the fibers ending in an optical connector matched to a 64 multianode photo multiplier tube (PMT) from the Hamamatsu ultra bialkali H8804-200MOD series (2 mm $\times$ 2 mm pixel size). The module enclosure will be made of PVC.

Before proceeding to install muon counters at the field in the Observatory site, it is convenient to bury and deploy a prototype in a field close to a laboratory environment within which the process can be conveniently validated under emulated AMIGA working conditions. The main objective of this work is to report on such a buried muon counter prototype.

3. Main objective & Procedure

A prototype was developed for AMIGA by Argonne National Laboratory (ANL) and FNAL. This module is 135 cm long, 75 cm wide (16 strips), and 1 cm thick with 1.2 mm WLS Kuraray green optical fiber glued in each strip groove. A 16 multianode Hamamatsu H8711-06 PMT was used with an 8 channel associated electronics board in order to acquire the PMT analogic signals.




Figure 3. Setup A & B: laboratory conditions and buried detector.
lhs: suspended lead column on the module prototype in the laboratory,
rhs: service pipe to gain access to the electronics.

To protect the electronic board and connections from humidity and corrosion, an ad-hoc enclosure box capable to endure buried conditions was designed and assembled. Figure 2 (*lhs*) shows details of the electronic enclosure with output (top wall) and power supply (side wall) connectors. The box is connected to the PMT which in turns links to the module via the optical connector to which the WLS fibers are glued. Data acquisition was performed with a Tektronix TDS 3032 digital oscilloscope (300 MHz of band width and 2.5 GS/s of sample rate).

The experiment was set to measure quasi-vertical impinging atmospheric muons and to ensure this, a time coincidence was requested. This coincidence was attained by adding to the experimental setup a short scintillator strip connected to a PMT inside a dark box. Its signals were channelled to the oscilloscope external trigger (see Figure 2 (*rhs*)).

With the purpose of understanding the effect of the soil over the muon counter we carried out two different experiments, with the counter set in the laboratory (setup A) and afterwards with the same counter buried in soil (setup B).

In setup A we set off by subjecting the prototype under stress for a period of a month by placing it underneath a 45 cm lead column in order to simulate the equivalent 540 g/cm^2 soil pressure (3 m deep with a soil density of 1.8 g/cm^3). Experiments were performed after this test in an effort to discard any module mechanical damage prior to burring it, stress damages over longer period of time were to be tested after burying the module. The lead stress was applied at the module center over an area four strip wide $\times$ 30 cm long. Also, and in order to avoid ground electromagnetic contamination, a lead shielding under the detector was used.

A test comparison was performed under the same shielding (i.e. amount of lead) causing and no causing stress, i.e. directly resting on the module or suspended just above it (see Figure 3 (*lhs*)). Results will be discussed in Sec. 4.

In setup B we repeated these conditions in a 3 m well excavated near the Tandar Laboratory, first making the measurements without dirt and then cov-

ering the detector with it. For a month the counter was kept buried during this stage of the experiment.




Figure 4. Charge Histograms as a result of the measurements made with setup A & B: comparison between results show similar features in all cases. *Top*: laboratory setup tested with and without stress. *Bottom*: buried prototype with and without dirt.

As a result of these different setups we had four different experimental conditions: lead suspended above and resting on the prototype, and underground with and without soil. On the *lhs* of Figure 3 we show the experimental setup mounted in the laboratory with a column of lead and the coincidence box, while on the *rhs* we show a detail of the service pipe (3 m tall 1 m diameter) installed to gain access to the buried electronics.

4. Results

Total charge histograms were performed integrating the pulses generated by each traversing muon. In order to study and compare different scenarios the histograms were normalized to the single photoelectron (spe) charge so the comparison can be made in terms of the spe for the four setups.

Figure 4 shows the normalized charge histograms for the prototype for each experiment layout, using one representative pixel of the PMT used. Fitting the zone associated with muon signals, we found a mean value of 10.55 ± 2.19 pe for the four setups, in agreement with our previous results (Krieger, 2008). The analyses show that the response of the buried prototype is the same as in laboratory conditions. So we conclude that the muon signal provided by our counter appears not been affected by neither applying stress or burying it in a 3 m well covered with soil, supporting the baseline AMIGA muon counters as a tool to establish the muon content of an extended air shower.

5. Conclusions

A new design and construction of a prototype electronic enclosure and its assembly onto the muon counter case was developed. Of more relevance was the design, construction and operation of the service pipe which will be used in AMIGA.

We made the first positive experiment in working conditions testing a muon counter and its electronics. We showed that burying the detector 3 m deep does not affect the measurements.

We also showed muon histograms do not change in either laboratory (with and without stress) or buried conditions.

References

- Abraham J., et al. (The Auger Collaboration), 2004, Nucl. Inst. & Meth., A523 50.
- Abraham J., et al. (The Auger Collaboration), 2008a, Phys. Rev. Letts. 101, 061101 1.
- Abraham J., et al. (The Auger Collaboration), 2008b, Astropart. Phys., 29, 188.
- Allekotte, I., et al. (The Auger Collaboration) 2008, Nucl. Inst. & Meth., A586, 409.
- Allard, et al. 2007, Astropart. Phys. **27**,61.
- Berezinsky, V., et al. 2004, Astropart. Phys. **21**, 617.
- Etchegoyen, A. (The Auger Collaboration) 2007, Proceedings of 30th ICRC (Mérida-México), #1307.
- Klages, H. (The Pierre Auger Collaboration) 2007, Proceedings of 30th ICRC (Mérida-México), #65.
- Krieger, A. 2008, personal communication.
- MINOS Collaboration, October 1998 “The MINOS Detectors Technical Design Report”, Version 1.0.
- Nagano, M. & Watson, A. 2000, Rev. Mod. Phys., Vol.72, No.3.
- Abraham J., et al. (The Auger Collaboration), 2008b, Nucl. Inst. & Meth., A586 409.
- Supanitsky, A.D., et al., Astropart. Phys., accepted for publication (arXiv:0804.1068v1).
- Tokonatsu, Y. (The Pierre Auger Collaboration), 2007, Proc.30th ICRC (Mérida-México), #318.
- Wibig, T., & Wolfendale, A., 2005, J. Phys. **G**, **31**, 255.